

# *Annual Drinking Water Quality Report for 2007*

## ***Candlewood Park***

*Candlewood Park Water District*

*266 Titicus Road*

*North Salem, NY 10560*

*Public Water Supply ID# NY5903449*

### **INTRODUCTION**

To comply with State regulations, The Town of North Salem Town Board, who is commissioners of the Candlewood Park Water District, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact VRI, Water Operator, 845-677-3839. We want you to be informed about your drinking water. If you want to learn more, please feel free to call the water operator.

### **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 156 people through 54 service connections. Our water source is made up of two groundwater wells, located within the Candlewood Park vicinity. The water is pumped into a 70,000-gallon holding tank and is gravity fed into the distribution system. The water is disinfected with sodium hypochlorite. No other chemicals are used in the treatment process.

The New York State Health Department has performed a Source Water Assessment, which follows. This discusses the susceptibility of contamination to your drinking water.

#### **Candlewood Park Water District**

NY5903449

AWQR Summary

The NYSDOH has completed a source water assessment for this system, based on available information. Possible and actual threats to the drinking water sources were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from 2-drilled wells. The source water assessment has rated these wells as having a medium-high susceptibility to microbials and nitrates. These ratings are primarily due to the close proximity of permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state government) to the well and the associated industrial activity in the assessment area, as well as residential land use and associated activities, such as fertilizing lawns.

A copy of the assessment, including a map of the assessment area, can be obtained by contacting the Town of North Salem.

## ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total Coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, might be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Westchester County Health Department at 914-813-5000.

**Table of Detected Contaminants**

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Microbiological	No	Monthly	ND				Leaching septic, sewer
POC, MTBE	No	2003	ND				Leaching gas, solvents
SOC's	No	2005	ND				Pesticides
TTHM's	No	2007	18.6	ug/L	80	80	
<i>Chlorodibromomthane</i>	No		2.6				
<i>Bromodichloromethane</i>	No		6.2				
<i>Chloroform</i>	No		9.8				
HAA5	No	2007	<6	mg/l	0.06	0.06	
<i>Dichloroacetic Acid</i>	No		0.0031				
<i>Trichloroacetic Acid</i>	No		0.0023				
<i>Inorganic Contaminants</i>							
Nitrates	No	2006	0.29	ppm	10	1	Runoff from fertilizer use; Leaching from septic tanks;
Nitrites	No	2007	ND	ppm	10	1	
Sodium*	No	2006	25.2	ppm	270		
Barium	No	2006	0.035	ppm	2.0		
Chloride	No	2006	69	ppm	250		
Iron	No	2006	0.018	ppm	0.3		
Nickel	No	2006	0.014				
Nitrate-Nitrogen	No	2007	0.22	ppm	10		
Odor	No	2006	2	T.O.N.	3		
Sulfate	No	2006	32	ppm	250		
Zinc	No	2006	0.028	ppm	5		
<i>Contaminants</i>							
Copper**	No	2006	0.159	ppm	1.3	1.3	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household Plumbing systems.
Lead**	No	2006	ND	ppb	.015	.015	Same as Copper
<i>Radiologicals</i>							Natural Uranium decomposition in the ground.
Radium 226 and 228	No	2007	1.37	pCi/L	5	5	
Radium – 228	No	2007	1.11	pCi/L	5	5	
GR Alpha and 226	No	2007	11.49	pCi/L	15	15	
GR – B	No	2007	7.07	pCi/L	15	15	
Uranium	No	2007	18.65	mg/l	30	30	

---

**Notes:** \*For individuals on severely sodium restricted diets, 20 mg/l, should not use this water for drinking.\*\* Lead and Copper: The level represents the 90<sup>th</sup> percentile. Ten samples were taken for lead and copper in 2006. All of the ten samples were below the MCL.

**Definitions:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL):** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Milligrams per liter (mg/l):** Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Picocuries per liter (pCi/L):** A measure of the radioactivity in water.

## WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations, but we have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

## IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2007, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

## DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

## WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ♦ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ♦ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ♦ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ♦ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ♦ Turn off the tap when brushing your teeth.
- ♦ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ♦ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

## CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.